



WHEN X = THE REQUIRED WIDTH

LANDINGS SERVING OCCUPANT LOADS OF 50 OR MORE

DOORS AT LANDINGS




R-3, U AND WITHIN
INDIVIDUAL DWELLING
UNITS OF R-1




ALL OTHER
OCCUPANCIES

LENGTH OF LANDINGS AT DOORS



X = LANDING WIDTH
Y = DOORWAY WIDTH
Z = STAIR WIDTH



X SHALL BE EQUAL TO OR GREATER THAN BOTH Y AND Z

WIDTH OF LANDINGS AT DOORS