


This figure illustrates the shortest path a supply cord of an appliance connected to the receptacle would follow without piercing the wall.



Acceptable receptacle locations within 20 feet of a swimming pool

In determining the above dimensions the distance to be measured is the shortest path the supply cord of an appliance connected to the receptacle would follow without piercing a floor, wall, ceiling, doorway with hinged or sliding door, window opening or other effective permanent barrier.

