




Community Development Permit Center CLEARANCES APPLIANCES (M24)


ONE TWIN PINES LANE,
SUITE 110
BELMONT, CA 94002
(650) 595-7422
www.belmont.gov

LAST REVISED:
2022 CA MECHANICAL CODE
802.8

BUILDING OFFICIAL:
DINO FRANCESCONI




ACCESS TO APPLIANCE FOR INSPECTION, SERVICE OR REPAIR



APPLIANCES 50,000 BTU OR LESS
OVER 50,000 BTU BUT NOT
EXCEEDING 65,000 BTU

9"
12"



OUTDOOR VENT TERMINATION—APPLIANCES WITH INTEGRAL VENTS